



Attestation of Conformity

No. T8A 101183 0018 Rev. 00

Holder of Certificate: Sunwoda Energy Solution Co., Ltd.

Room 201, Building C, Sunwoda Electronic Factory

Tangjia Community, Fenghuang Street

Guangming District 518100 Shenzhen City

PEOPLE'S REPUBLIĆ OF CHINA

Product: Batteries

(Rechargeable Lithium Iron Phosphate

Battery System)

This Attestation of Conformity is issued on a voluntary basis in support of the Conformity Assessment Module A of Radio Equipment Directive 2014/53/EU. On the basis of the referenced test reports, the samples of the listed product were found to comply with the essential requirements of the above mentioned directive as implemented in the standards used valid at the time the tests were carried out. For the requirements of the Article(s) 3(2) and 3(3) only harmonized standards valid at the moment of issuing where used. The used standards cover the essential requirements of the Radio Equipment Directive as applicable to this product. The manufacturer must ensure compliance of the manufactured products with the technical documentation and other requirements of the Radio Equipment Directive that apply to them. National legal requirements have to be considered before bringing the product to the market. For details see: www.tuvsud.com/ps-cert

Test report no.: 64771226038001

Date, 2022-09-09

(Peter Jia)

Page 1 of 2

After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives the manufacturer may sign a Declaration of Conformity and apply the CE-marking.







Attestation of Conformity

No. T8A 101183 0018 Rev. 00

Model(s): Atrix-5, Atrix-5B, Atrix-10, Atrix-10B, SB5110, Atrix-

15, Atrix-15B, SB7615, Atrix-20, Atrix-20B, SB1220

Parameters: Ratings:

B051100P02, SB51V100Ah-R, Atrix-5, Atrix-5B: 51.2Vd.c., 100Ah;

Atrix-10, Atrix-10B, SB5110: 51.2Vd.c., 200Ah; Atrix-15, Atrix-15B, SB7615: 51.2Vd.c., 300Ah; Atrix-20, Atrix-20B, SB1220: 51.2Vd.c., 400Ah

Remark:

B051100P02, SB51V100Ah-R are the battery module

of battery system Test report No.: 64.771.22.60380.01R

(EN 300 328 V2.2.2:2019, EN 62311:2008)

64.771.22.60380.01

(EN 301 489-1 V2.2.3:2019, EN 301 489-17 V3.2.4:2020,

EN IEC 61000-6-3:2021, EN IEC 61000-6-1:2019)

085-282260216-000 (IEC 62619:2017)

Tested EN 300 328 V2.2.2:2019

according to: EN 62311:2008 FN 301 489-1 V

EN 301 489-1 V2.2.3:2019 EN 301 489-17 V3.2.4:2020

EN IEC 61000-6-3:2021 EN IEC 61000-6-1:2019

IEC 62619:2017



After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives the manufacturer may sign a Declaration of Conformity and apply the CE-marking.